

Alpine Convention
Platform water management in the Alps

ALPINE SIGNALS FOCUS 1

**COMMON GUIDELINES
FOR THE USE OF SMALL HYDROPOWER
IN THE ALPINE REGION**

IMPRINT

Author:

Platform Water Management in the Alps
A Platform within the Alpine Convention

Translation:

French, German, Italian and Slovenian translations: Intralp
Original version in English
English revision: Stephen Goodwin

Publisher:

Permanent Secretariat of the Alpine Convention
Secretary General: Marco Onida
Coordination: Regula Imhof and Marcella Macaluso
info@alpconv.org
www.alpconv.org

Main office:

Herzog-Friedrich-Straße 15
A-6020 Innsbruck - Austria

Branch office:

Viale Druso – Drususallee 1
I-39100 Bolzano – Bozen
Italy

Graphics and Printing: Longo (BZ, Italy)

Cover photos:

© Marc Baumgartner
© Energie AG Oberösterreich
© Bundesamt für Umwelt Schweiz/AURA

ISBN: 9788890515880

© Permanent Secretariat of the Alpine Convention, 2011

Members of the Platform Water Management in the Alps

Co-Presidency:

Austria

Karl Schwaiger; Federal Ministry of Agriculture, Forestry, Environment and Water Management, Unit VII/2 – International Water Policy

Switzerland

Martin Pfandl; Federal Office for the Environment, Water Division

National Representatives and further Participants of the Member States:

Austria

Raimund Mair, Karl Kriechenbaum and Jakob Schrittwieser; Federal Ministry of Agriculture, Forestry, Environment and Water Management, Unit VII/2 – International Water Policy

France

Berengère Charnay

Germany

Erich Eichenseer Bavarian State Ministry of the Environment and Public Health, Unit Water Management in Rural Regions; in coordination with Martin Popp, Bavarian Environment Agency Unit 62, Dams and Reservoirs, Hydraulic Structures, Hydro Engineering Technology

Italy

Pietro Colonna, Donata Balzarolo and Andrea Bianchini, Ministry of Environment, Territory and Sea

Liechtenstein

Egon Hilbe, Office of Environmental Protection, Unit Water Management

Slovenia

Mitja Bricelj, Ministry of the Environment and Spatial Planning, Spatial Planning Directorate

Switzerland

Patrizia Dazio and Hugo Aschwanden, Federal Office for the Environment, Water Division

Further Members and Participants to the Meetings:

AEM (European Association of Elected Representatives from Mountain Regions) Andrea Mammoliti Mochet

CIPRA International (International Commission for the Protection of the Alps) Cornelia Maier

Club Arc Alpin Liliana Dagostin

ESHA (European Small Hydropower Association)

Martina Pechtl, Sara Gollessi, Luigi Papetti and Gema Sanbruno

ISCAR (International Scientific Committee on Research in the Alps) Leopold Füreder

MRI (Mountain Research Initiative) Klaus Jorde



ALPINE SIGNALS FOCUS 1

COMMON GUIDELINES FOR THE USE OF SMALL HYDROPOWER IN THE ALPINE REGION

Alpine Convention
Platform water management in the Alps

INDEX

1	Introduction	5
1.1	Assignment and content of the guidelines	5
1.2	Initial Situation	6
1.3	Objectives	7
1.4	Scope of application	8
1.5	Addressees	8
2	General Principles	9
2.1	Sustainability	9
2.2	Common Alpine wide principles and specific national / regional approaches	10
2.3	Reference Situation	10
3	General recommendations	11
3.1	Types of Small Hydropower Plants	11
3.2	Off-grid small hydropower plants	12
3.3	New Construction or Refurbishment	12
3.4	Outline of a two-level procedure assessing new installations	14
3.4.1	The regional level: Strategic planning	14
3.4.2	The local level: At-site assessment and authorisation of individual projects	16
3.4.3	Implications from the regional strategic planning as prerequisite for the local assessment and authorisation	17
4	Guidance for an evaluation Procedure for new Installations	18
4.1	Overview	18
4.2	The regional strategy: classification of river stretches with respect to potential appropriateness for SHPs	19
4.2.1	Criteria for the evaluation of the theoretical hydroelectric potential	19
4.2.2	Criteria assessing the ecological and landscape value	20
4.3	The local assessment for new installations: Evaluating the site- and project-specific pros and cons	21
4.3.1	Installation- and site-specific criteria	22
4.3.2	Further socio-economic criteria	22

ANNEX 1: GOOD PRACTICE EXAMPLES (available at www.alpconv.org)

ANNEX 2: INSPIRING INTERNET LINKS ON SMALL HYDROPOWER AND GUIDANCE DOCUMENTS
(available at www.alpconv.org)

1 INTRODUCTION


1.1 Assignment and content of the guidelines

Based on the Mandate from the Xth Ministerial Conference of the Alpine Conference in Evian, March 2009 and referring to the Climate Action Plan approved at the Xth Ministerial Conference of the Alpine Conference in Evian, March 2009, the Platform Water Management in the Alps (PWA) has worked out **common guidelines on the use of small hydropower** including good practice examples. These common guidelines have been approved by the XIth Alpine Conference held in Brdo pri Kranju (Slovenia) in 2011.

At first, this requires defining the term small hydropower. As a general rule, small hydropower is defined according to the installed bottleneck capacity. Such a technical definition of small hydropower is also used as a threshold value for legal and economical aspects (legal frame for environmental impact assessments (EIA), entitlements for subsidies, etc.)

Currently there is no international consensus on a technical threshold value defining the boundary between small and large hydropower (see e.g., the different thresholds set in the individual Alpine countries, varying from 1 to 10 MW¹). Therefore, this document refers to small hydropower in principle with respect to the thresholds of installed capacity as defined in the legal frame of the individual countries.

The present guidelines on the use of small hydropower include common principles and recommendations, an outline for an assessment procedure as well as a pool of evaluation criteria. However, no concrete methodology is proposed since sufficient flexibility for implementation of the guidelines is needed in order to pay attention to regional differences and varying national boundary conditions. To underpin the guidelines, Good Practice Examples with concrete methodologies are presented in Annex 1².



The common guidelines have to be considered along with the existing national/regional legal frameworks and instruments. To that end, Annex 2 provides a compilation of links to national and regional guidance documents.

As guidelines they have the character of recommendations but do not exert any legally binding force.

Figure 1: Potential levels of detail for guidelines. The red box indicates the target of the common guidelines

¹ See Table 1 of the Situation Report on hydropower generation in the Alps focusing on small hydropower

² As an example of concrete methodology, the Interreg Alpine Space Project "SHARE" (Sustainable Hydropower in Alpine Rivers Ecosystems) is going to develop, test and promote a decision support system to merge river ecosystems and hydropower requirements in accordance with norms and operated by permanent panels of administrators and stakeholders - www.share-alpinerivers.eu

1.2 Initial Situation

Due to the high hydroelectric potential on the one hand and the important value of ecosystems and landscape on the other hand, the use of small hydropower in the Alpine area results in a conflict of interests between the use of renewable energy and the protection of the aquatic ecosystems and landscapes. A further aspect is that river stretches which are in or near a genuinely natural state have become increasingly rare.

In order to reduce emissions of greenhouse gases, energy legislation (RES-e³ / EnG⁴) contains quantitative goals for renewable energy growth. For the Alpine area, the contribution of hydropower production is considered to be particularly important for electricity production by using renewable energy resources. This is why in most Alpine countries specific national goals for the growth of hydropower production are set and an increasing pressure on remaining river stretches can be perceived.

The actual exploitation level of hydropower production in the Alpine area is significant. The remaining hydro-electrical potential depends on the still unutilised river stretches and discharge, thus entering into potential conflicts with the conservation of ecosystems and landscapes. Given the rarity of remaining unexploited rivers, strategic reflection is of the utmost importance in order to avoid irreversible impacts.

Given the multiplicity of pressures and conflicting expectations with respect to small hydropower in the Alpine region (see figure 2), this is why decision makers and authorisation bodies are in need of, and have asked for, guidelines to tackle this challenging issue. This has also been outlined in the conclusions of the situation report on hydropower generation in the Alps focusing on small hydropower.



Figure 2: Hydroelectric potential and ecosystem potential in the Alpine region: Area of conflict with different pressures and expectations.

³ Directive 2009/28/EC of the European Parliament and of the Council of 23 April 2009 on the use of energy from renewable sources and amending and subsequently repealing Directives 2001/77/EC and 2003/30/EC

⁴ Swiss Federal Energy Act dated 26 June 1998 (SR 730.0)

1.3 Objectives

Derived from both the energy and environmental legislation, **the general objectives** with respect to the use of small hydropower are

Increasing the production of renewable energy from hydropower generation

Minimising the impairment of the aquatic ecosystem and landscape

The main challenge for the forthcoming years is to put in place the amount of renewable energy enshrined in national plans, requiring the identification of those locations which possess the necessary hydroelectric potential and where the impairment of ecosystems and landscape is low or at least acceptable.

In many cases this raises a conflict of interest that requires a balance to be struck between these two objectives. This implies the search for locations that are potentially favourable for hydropower and the identification of locations that are ecologically sensitive, rendering them less favourable for hydropower use. The appropriateness of locations for small hydropower plants is thus in principle based on an assessment of utilisation and conservation criteria. The decision needs to be based on a holistic evaluation, i.e. considering socio-economic and ecological criteria.

Since the decision on a new project is usually within the responsibility of the public authority based on a request by the applicant, the optimisation task between the two objectives falls also within the responsibility of the public authority. This requires assistance through guidelines both for the public authority responsible for taking the decision and for potential applicants by making the decision process transparent in advance and providing an indication on the prospects of a project being realised.

In general terms, the specific objective of the guidelines is therefore to provide general guidance for the identification of potential favourable locations for small hydropower plants and the subsequent authorisation decision in accordance with the sustainability principles in order to reach the renewable energy growth goals.

This is in line with the objectives of the energy protocol⁵ of the Alpine Convention, which aim to establish sustainable development in the energy sector compatible with the Alpine region's specific tolerance limits. According to this protocol, remaining energy needs should be met by making a wider use of renewable energy sources, encouraging the use of decentralised plants. However, negative effects of new and existing hydroelectric plants on the environment and the landscape have to be limited by adopting appropriate measures to ensure that the ecological functions of watercourses and the integrity of the landscape are maintained.

Moreover, the specific objective of the guidelines is also supported by the proposed measures of the "ArgeAlp" at the 40th Intergovernmental Conference⁶ (June 2009), recommending the promotion of small hydropower through information on its possibilities and by identification of suitable sites, taking into account the particular ecological sensitivity of the Alpine area.

The specific objective of the present guidelines can therefore be addressed as

To provide general guidance for the identification of potentially favourable locations for small hydropower plants and for the subsequent authorisation decision considering the principles of sustainable development in the Alps.

⁵ www.alpconv.org/NR/rdonlyres/77274D16-B20C-43F0-9E20-2C6DA92F68D4/0/EnergyProtocolEN.pdf

⁶ www.argealp.org/fileadmin/www.argealp.org/downloads/deutsch/Resolution_Energiepolitik_de.pdf

As an ambitious approach for the whole Alpine area, the guidelines have the potential to back up regional planning authorities and to consolidate the principles of integrated water resources management. Furthermore, this document may also contribute towards the objective of highlighting effective and sustainable ways on how to make the Alpine area climate neutral by 2050, as indicated in the Climate Action Plan of the Alpine Convention.

The guidelines in hand are intended to address the described conflict of interest. Depending on the particular area under scrutiny it has to be kept in mind that other water uses may be relevant as well and need to be considered within this optimisation task.

1.4 Scope of application

The present guidelines' scope is

- geographically, the perimeter of the Alpine Convention (i.e. the Alps);
- addressing in particular small hydropower (according to the technical / legal definition in the individual countries⁷);
- recommendations for the authorisation of applications for new small hydropower plants (SHP);
- as guidelines they have the character of recommendations but do not exert any legally binding force

These points define the guidelines' scope of application in a narrow sense. In a broader sense the guidelines' principles may also have validity

- outside the Alpine region for other countries and mountain areas facing the same conflicts;
- for hydropower in general; however, other aspects and criteria have to be considered with respect to large hydropower (e.g. grid stability, peak electricity supply, etc), which are not dealt with in these guidelines;
- for analysing the optimisation potential of existing installations;
- in their character of common Alpine-wide guidelines they serve as an orientation and reference document for developing comparable procedures and having similar standards in the Alpine Convention member states.

1.5 Addressees

These guidelines are addressed in the first place to the public bodies responsible for strategic planning and in charge of authorising small hydropower plants

- for strategic planning activities;
- as decision support for assessing individual small hydropower plant projects.

Furthermore, they may serve as orientation for applicants of small hydropower projects about the chances of getting an authorisation and more specifically about aspects that should be considered in the design of projects (i.e. support for potential investors and efficient planning) and also as common vision for the realisation of small hydropower throughout the Alps.

⁷ The threshold value defining small and large hydropower is variable by country, ranging between 1 and 10 MW

2 GENERAL PRINCIPLES

2.1 Sustainability

In accordance with the principles of sustainable development⁸, resources should be managed in a holistic way, coordinating and integrating environmental, economic and social aspects.




Figure 3: The three components of sustainability

To strike a balance between the general objectives of “increasing the production of renewable energy from hydropower generation” and “minimising the impairment of the aquatic ecosystem and landscape”, a weighing of the interests based on sustainability criteria has to be carried out. The whole hydropower sector has the potential to contribute towards the achievement of sustainable development; the role of small hydropower within this sector is to be considered under the framework of the guidelines in hand.

Alongside hydropower production and conservation of the aquatic ecosystems and landscapes, the following aspects also have to be considered:

- other national or regional objectives and constraints (social, legal, economic, financial);
- general environmental aspects including objectives regarding climate protection (e.g. ecosystem services);
- other water uses (e.g. water supply, irrigation etc);
- socio-economic aspects: allocation of revenues, decentralised approaches, employment, social development of the region, tourism etc

Recommendation 1

To strike a balance between an increase of hydropower generation and environmental protection, a transparent weighing of the interests based on sustainability criteria has to be carried out

⁸ United Nations General Assembly (2005). 2005 World Summit Outcome, Resolution A/60/1, adopted by the General Assembly on 15 September 2005. Retrieved on: 2009-02-17; <http://daccess-dds-ny.un.org/doc/UNDOC/GEN/N05/487/60/PDF/N0548760.pdf?OpenElement>

2.2 Common Alpine-wide principles and specific national / regional approaches

The present guidelines suggest some general recommendations and standard aspects for the whole Alpine region. However, in order to be in line with existing legal frameworks and instruments, national and regional factors and conditions have also to be considered. Thus, next to standard aspects for the whole Alpine region, specific national / regional approaches built on the basis of common principles have to be established.

Nevertheless, as indicated in chapter 1, the ambition of this document is not to develop and recommend one single specific method or concrete procedure for the whole Alpine region. Rather, the idea is to agree on general principles - including a common understanding of the most important evaluation criteria - for the whole Alpine region that permits a flexible implementation in accordance with the specific national or regional situation.

Recommendation 2

National / regional approaches dealing with small hydropower in the Alps should be built on the basis of common principles, general considerations and standard aspects for the whole Alpine region but should also consider specific national and regional factors.

2.3 Reference Situation

When evaluating the ecological value of a location, the question arises if the status quo or a potential status should be regarded as the base reference situation. To consider only the existing situation would be to neglect potential improvements of the ecological value due to, for example, planned river revitalisation projects or any other ecological enhancement plans (as may be foreseen as objectives in River Basin Management Plans⁹).

Recommendation 3¹⁰

When assessing the ecological value of river stretches, not only the status quo needs to be taken into account but also foreseeable changes to the ecological condition if e.g. rehabilitation projects are foreseen.

When evaluating the ecological value of a location, not only the individual situation of the river stretch itself, but also its ecologic importance within the whole river system has to be considered.

Recommendation 4

When assessing the ecological value of a river stretch it needs to be considered whether it has a specific ecologic importance for the other stretches in the river basin.

⁹ Overview of River Basin Management Plans: http://ec.europa.eu/environment/water/participation/map_mc/map.htm

¹⁰ Good Practice Example "Evaluation and management of the hydroelectric potential of the Canton of Fribourg" provided in Annex 1, illustrates this recommendation

3 GENERAL RECOMMENDATIONS

3.1 Types of Small Hydropower Plants

Considering the differences of ecological impacts depending on the plant type, a distinction between the following types is proposed:

- Run-of-river power plants;
 - Diversion hydroelectric plant: plants involving an abstraction and diversion of water;
 - Through-flow power plant: plants with no diversion but run-through regime;
- Infrastructure-related power plants, also called multipurpose plants (integrated in the network of the drinking water supply, waste water disposal infrastructure or irrigation infrastructure as well as residual flow hydroelectric plants or for the creation of flows to aid fish migration). This type of SHP is understood as being located in installations that primarily have a goal other than electricity production and that are exploiting for hydroelectric purposes water that is already used by the primary goal but not additionally abstracting water. Compared to run-of-river power plants, the power output of these plants is marginal.

Figure 4: Examples of small hydropower plants



Diversion hydropower plant¹¹



Through-flow hydropower plant¹²



Drinking water supply hydropower plant¹³



Residual flow hydropower plant¹⁴

Recommendation 5¹⁵

Infrastructure-related hydropower plants, exploiting only the water that is already used by the primary purpose of the plant, are in general not additionally affecting aquatic ecosystems and are economically favourable. Thus, from an environmental point of view, such multipurpose small hydropower plants are in general considered appropriate and desirable.

¹¹ Water abstraction on Dora Baltea river, Aosta Valley (Italy) ©A. Mammoliti Mochet

¹² Hydro power plant Agonitz (Austria) © Energie AG Oberösterreich

¹³ Small hydropower plant on drinking water supply network of Troistorrents (Switzerland). © MHyLab

¹⁴ Hydropower Plant Vils, Municipal utilities of Vilshofen; Hydro Power Snail; © State Office for Water Management Deggendorf.

¹⁵ Various Good Practice Examples provided in Annex 1 illustrate this recommendation

3.2 Off-grid small hydropower plants

For remote locations requiring electricity supply where connection to the public electricity grid would lead to disproportionate costs and better environmental options are not feasible, there is a need for self-supply by hydropower. This constitutes a prevailing argument in the weighing of interests. On the other hand, for locations that can be supplied from the public grid and for SHP that feed into the public grid, the argument of self-supply production is not valid.

Recommendation 6

In the weighing of interests, the purpose of the SHP needs to be given due consideration: In particular, the provision of electric self-supply, where connection to the public grid would be at disproportionate cost and no better environmental options are given, constitutes a strong argument in favour of building SHP in remote individual locations, such as, for example, alpine huts and farms.



Figure 5: St. Martin, a settlement in the Alps (Canton of Graubünden, Switzerland) without connection to a public electricity network. Electricity production by a small hydropower installation. © Programm Kleinwasserkraftwerke¹⁶

3.3 New Construction or Refurbishment

The construction or refurbishment of small hydropower facilities can be driven by a variety and combination of motives, such as an increase in the contribution towards renewable energy supply, the achievement of climate objectives or the self-supply of individual remote locations.

For the evaluation of the impact of a small hydropower plant, the following cases need to be distinguished:

Existing installations:

- Refurbishment of an existing, operating plant (renovation, expansion, electrification) within the validity of the existing concession;
- Reopening / reactivation of a disused hydroelectric plant;
- Renewal of a concession / license for exploiting water resources;
- Important refurbishment or upgrading of an existing, operating plant (renovation, expansion, electrification) where a new concession is needed.

¹⁶ www.smallhydro.ch/bdb/displayimage.php?pos=-182

New installations:

- Construction of a new plant at a previously unused location;
- Reconstruction of a dismantled plant at a formerly used location.

Small hydropower plants already in place usually do not lead to further environmental deterioration when refurbished. Therefore **refurbishment of existing operating plants within the validity of the existing concession** can generally be considered as appropriate and should be prioritised before building new installations. Furthermore, according to article 7.4 of the energy protocol of the Alpine Convention, **reopening disused hydroelectric plants** should be recommended rather than building new ones.

However there should be a periodic examination as to whether further mitigation of negative impacts and better compliance with existing environmental legislation can be achieved by the application of best practice without entailing disproportionate costs.

Recommendation 7

Refurbishment of existing operating plants and reopening of disused plants in order to optimise the production of hydropower while minimising ecological impacts should be promoted and prioritised. However there should be a periodic examination as to whether further mitigation of negative impacts and better compliance with existing environmental legislation can be achieved by the application of best practice without entailing disproportionate costs.

Recommendation 8¹⁷

Ecological upgrading of existing operating plants in order to mitigate the impacts on an area's ecological status and landscape should be promoted by means of incentives in order to accelerate the fulfillment of legal requirements earlier or even to go beyond these minimal requirements.

Existing and operating small hydropower plants that require a **renewal of the concession or license** can generally be considered appropriate, since it is expected that this would not lead to a further environmental deterioration. Since the renewal of the water right would have to be in accordance with the current environmental legislation and best practice, its granting should in general entail a mitigation of negative impacts.

Given that over a period of time, technical approaches, views and environmental standards can change, concessions and licenses should be time limited in order to enable an active management of water resources. However, this limitation has to be in balance with the necessary stability of granted rights in order to secure the protection of financial investments in hydropower facilities.

Recommendation 9

Renewal of concessions or licenses can be considered appropriate where it complies with the existing environmental legislation. Nevertheless the ecological potential of the site should be considered and concessions or licenses should be limited in time, being as short as possible without compromising the investment.

Important refurbishments or upgrading of existing operating plants (e.g. asking for an increased water abstraction), requiring a new concession may lead to further environmental deterioration; therefore such cases should be evaluated with the same procedure applied to **new installations** described in chapter 3.4.

¹⁷ See e.g. naturemade certification: the quality mark for ecologically produced energy (naturemade star) and energy from renewable sources (naturemade basic). www.naturemade.ch

3.4 Outline of a two-level procedure assessing new installations

In most countries of the Alpine Convention, quantitative goals to increase hydroelectric production have been introduced in energy legislation. To achieve these goals and the environmental goals also set out in existing legislation, favourable locations and technical solutions for hydroelectric production have to be identified. The key question is therefore: **where** are the most favourable locations to build and operate SHP in order to achieve those goals.

However, the evaluation for authorisation of small hydropower depends not only on a favourable location but also on the individual project application and specific local circumstances. Different project concepts at one site may lead to different ecological impacts and exhibit different socio-economical benefits. Thus, a differentiation of the individual installation is necessary in order to judge not only if projects should be authorised in certain areas or not but also on how they should be realised.

The concept is therefore to go from general to detail (from regional to local). The following subsections describe the outline of a transparent procedure on two levels for identifying where to realise most appropriately the increase in hydroelectric production by small hydropower plants and which individual solution should be the most suitable.

- Chapter 3.4.1 sets out the procedure's first level: a general evaluation of the appropriateness of stretches of a particular river for hydropower use in terms of a strategic planning for a geographic region, independently from individual applications (regional¹⁸ level).
- Chapter 3.4.2 sets out the second level: the project specific evaluation of the local situation and the individual application (local level).
- Chapter 3.4.3 sets out the implications from the regional strategic planning as prerequisite for the local assessment and authorisation.

Recommendation 10¹⁹

In order to answer the questions about the “where”, with respect to the most favourable sites to reach growth objectives for hydroelectric production, and the “how”, with respect to the individual project, a transparent, structured and criteria-based procedure that combines a regional/strategic point of view with a local, project-specific assessment should be applied.

In some countries of the Alpine Convention, authorities for strategic planning and for granting concessions are different. In such an institutional context it is important that authorities responsible for granting concessions are also involved in the strategic process.

Recommendation 11

The development of the regional strategy is a process triggered by the competent authority. In order to ensure transparency and to find a solution that takes account of the different interests at stake, the relevant stakeholders' views must be adequately involved by means of a participative procedure.

This is also in line with Article 4 of the Energy Protocol²⁰ of the Alpine Convention, aiming at the participation of regional and local authorities in the process of applying energy policies in order to ensure coordination and cooperation. The regional and local authorities directly concerned shall be parties to the various stages of preparing and implementing energy policies and measures, within their competence and within the existing institutional framework.

While this chapter provides the outline, chapter 4 provides more concrete guidance for such a two-level evaluation procedure.

¹⁸ In this context the term “Regional” means to go beyond the local project-specific perspective and refers to a wider spatial context: be it in a geographical sense, e.g. a river basin, be it a provincial/cantonal territory.

¹⁹ Good Practice Example “Strategy “water use” of the Canton of Bern” provided in Annex 1, illustrates this recommendation. Such an approach is also foreseen by the national recommendation of Switzerland (www.umwelt-schweiz.ch/UD-1037-E)

²⁰ www.alpconv.org/NR/rdonlyres/77274D16-B20C-43F0-9E20-2C6DA92F68D4/0/EnergyProtocolEN.pdf

3.4.1 The regional level: Strategic planning

In order to provide an answer to the “where” question, the evaluation’s horizon has to be broadened: it is about the search for the most favourable locations, which necessarily takes place on a **regional level**. Favourable locations are those that exhibit a high hydro-electric potential while also being of relatively low ecological and landscape value or where the ecological status would not be significantly degraded by appropriate hydropower use. “Regional” in this context means to go beyond the local project-specific perspective and refers to a wider spatial context: be it in a geographical sense, e.g. a river basin, or in a provincial/cantonal/national territory.

Within this wider spatial context the evaluation of the potential appropriateness for hydropower use of the river stretches of a given region is carried out, irrespective of concrete applications. This evaluation is based on the comparison of the theoretical hydro-electrical potential on the one hand with the ecological and landscape value on the other hand, leading to a classification of river stretches with respect to the potential appropriateness for hydropower use. Classification is e.g. in three categories: favourable, less-favourable and non-favourable for hydropower use.

The process to establish such a strategic planning is triggered by the competent authority and implies the involvement and consultation of relevant stakeholders (see recommendation 11). This constitutes the basis for a coordinated development of small hydropower for the given region and catalyses a transparent dialogue between the user’s perspective and the conservation point of view, identifying the most favourable locations for SHP as well as those less and unfavourable.

Recommendation 12

Strategic planning on a regional level (regional strategy):

On a regional level, a transparent evaluation and classification of the potential appropriateness of river stretches for hydropower use shall be carried out (considering hydro-electric potential, ecological and landscape value and areas under special protection).

The actual exploitation level of hydropower production in the Alpine area is significant. The remaining hydro-electrical potential depends on the extent of unutilised river stretches and discharge and on further specific functions of the river stretch that limit exploitation. Therefore, if there remain only a few areas (e.g. sub-basins) that so far have not been used within a greater perimeter (e.g. a river basin, a province or a canton), there may be the wish to preserve such rare areas.

Recommendation 13

As part of the regional strategy, the designation of areas that are deliberately kept free from any exploitation, avoiding irreversible impacts, should be considered. This has to be based on a broad participation of relevant stakeholders as outlined in Recommendation 11.

The outcome of this regional pre-planning with classified river stretches is a **regional strategy** for the development of SHP and provides a framework for the assessment and authorisation of individual projects. Such a regional strategy is an effective and transparent decision making instrument which can also be used for communication purposes, indicating the chances and potential requirements for an authorisation. It is recommended that the regional strategy should be of a binding character. To this end, consideration should be given to integrating the strategy into existing instruments like the WFD-river basin management plans²¹ or into other spatial planning instruments.

²¹ Overview of River Basin Management Plans: http://ec.europa.eu/environment/water/participation/map_mc/map.htm

Recommendation 14

Possible ways on how to integrate the elaborated results of the strategic planning in existing national / regional instruments shall be examined (e.g. river basin management plans or spatial planning instruments).

Such regional pre-planning meets the requirements of the WFD, where Article 4.7 sets out the conditions for exceptions for deterioration of water status or failure to achieve good water status. In particular letter c) of article 4.7 asks for a weighing of benefits, balancing the benefits of modifications with the benefits of water protection or to the public interest. Letter d) asks for the examination of better environmental options to reach the objective of the water body's modification.

The common implementation strategy of the WFD recognises therefore the need to address this issue at a strategic – regional level²². In consideration of the “no better environmental option” not only the single project and locality but also the whole region or catchment has to be taken into account. The regional strategy outlined above is therefore in line with the WFD provisions. A regional strategic planning based on a weighing of interests and classifying river stretches as favourable, less favourable and not favourable for hydropower use can be seen as response to the requirement of examining better environmental options to justify exemptions according to article WFD 4.7.

Such an approach is endorsed by the communication on the support of electricity from renewable energy sources (COM(2005) 627)²³ as well as the Note of the EU Water Directors on “Hydropower Development under the Water Framework Directive”²⁴ and by the Policy Paper from 2007 on “WFD and Hydro-Morphological pressures”²⁵, recommending the development of pre-planning mechanisms to allocate suitable areas for new hydropower projects. Practical examples could be allocating suitable areas for hydropower development by identifying sites where new plants would be both acceptable in terms of water protection and economically beneficial. Such pre-planned hydropower areas could be the target of financial support schemes for hydropower development.

Also the SHERPA project (Small Hydro Energy Efficient Promotion Campaign Action²⁶) – a project funded by the EU in the framework of the Intelligent Energy for Europe Programme with, amongst others, a number of small hydropower associations as partners – points out in its conclusions the advantage of pre-planning mechanisms at river basin level to facilitate the identification of suitable areas for new hydropower projects. The use of such pre-planning systems could also streamline the authorisation process and lead to faster implementation. For this pre-planning a categorisation of areas with respect to suitability for hydropower use is proposed, with all stakeholders to be involved in the identification of the categories.

3.4.2 The local level: At-site assessment and authorisation of individual projects

Going from general to detail, the regional strategy and pre-planning provides the information on the general appropriateness of a river stretch for hydropower exploitation. As pointed out in chapter 3.4.1, this classification considers the hydroelectric potential on the one hand and the ecological and landscape value on the other hand. This may in many cases already provide the necessary information to decide if projects located at specific river stretches should to be assessed in more detail or not. Especially for projects situated along areas classified as non-favourable for hydropower exploitation, the procedure may in many cases stop at this point.

The regional pre-planning is however still a general, coarse assessment without consideration of project- and detailed

²² See e.g. the conclusions from the 2007 Berlin Workshop on Water Framework Directive and Hydropower: www.ecologic-events.de/hydropower/

²³ http://ec.europa.eu/energy/res/biomass_action_plan/doc/2005_12_07_comm_biomass_electricity_en.pdf

²⁴ http://circa.europa.eu/Public/irc/env/wfd/library?l=/framework_directive/thematic_documents/hydromorphology/development_directivepdf/_EN_1.0_&a=d

²⁵ http://circa.europa.eu/Public/irc/env/wfd/library?l=/framework_directive/thematic_documents/hydromorphology/hydromorphology/_EN_1.0_&a=d

²⁶ www.esha.be/sherpa or more precisely: www.esha.be/fileadmin/esha_files/documents/SHERPA/D22_Report_WFD_RESe_EN.pdf

site-specific information. If a request for authorisation of a specific project is submitted to the competent authority, the regional strategy does of course not substitute any authorisation decision but is only the frame for the local assessment since the scale is too wide to allow for final decision about a specific small hydropower project. Built on the general appropriateness of the river stretch, a more in-depth assessment using project- and site-specific characteristics and further socio-economic aspects is necessary, also looking at the “how” of the project. Further, combining the local level with the regional perspective enables consideration of the cumulative effects of several facilities.

To sum up, the result of the local assessment is the **decision about authorisation of a project**, considering all sustainability aspects with a broad weighing of all relevant criteria.

Such local assessments have of course to be in line with existing assessment instruments like e.g. environmental impact assessments²⁷.

Recommendation 15

Authorisation decision on a local level - For individual applications only:

The second level of the proposed evaluation procedure is a local in-depth assessment of the concrete project application, considering installation- and detailed site-specific criteria and further socio-economic aspects such that a holistic weighing of all relevant criteria is carried out.

The authorisation is not just about judging if projects should be allowed in certain areas or not but also about how projects should be realised.

3.4.3 Implications from the regional strategic planning as prerequisite for the local assessment and authorisation

The proposed procedure for the evaluation and authorisation process for hydropower plants foresees the strategic planning on a regional level as a first step and prerequisite for the local assessment as a second step. This implies that the second step – which includes the actual authorisation – should wait until the results from the regional pre-planning are available in order to avoid irreversible impacts. Strictly speaking this would mean a suspension of any authorisation in the meantime, since the strategic planning requires a certain time span.

However, given the defined goals concerning the increase in electricity production from small hydropower within certain time limits, such a general suspension would risk failing to reach those goals in due time. Therefore, a pragmatic approach is suggested, where the normal authorisation procedure can be carried out for “evident cases” without regional pre-planning. Such cases comprise SHP-projects where it is evident that they do not cause a significant impact on and deterioration of the ecosystem or where SHP-plants even lead to an ecologic improvement compared to the status quo. These cases mainly refer to infrastructure-related facilities and refurbishment projects (see Recommendation 5 and Recommendation 7) that would not require the results of a regional planning exercise prior to the site-specific authorisation procedure.

Recommendation 16²⁸

Being a prerequisite for the local assessment and decision about an individual project application, the regional strategy /planning should be carried out as soon as possible.

²⁷ See also Annex 1 of the Situation Report on Hydropower Generation in the Alps focusing on Small Hydropower - National questionnaires on hydropower generation in Alpine Countries, Point 3.3.2.

²⁸ Good Practice Example “Evaluation and management of the hydroelectric potential of the Canton of Fribourg” provided in Annex 1, illustrates this recommendation

4 GUIDANCE FOR AN EVALUATION PROCEDURE FOR NEW INSTALLATIONS

4.1 Overview

This chapter provides more in-depth guidance for the two-level procedure (that has been outlined in chapter 3.4) for the assessment of new installations.²⁹

The first, regional level is based on the comparison of the ecological and landscape value on the one hand with the hydro-electrical potential on the other hand. Such a strategic planning on a regional level considers these two aspects and provides a gross classification of river stretches with respect to their potential appropriateness as location for small hydropower plants.

Criteria and suggestions

- to determine the hydro-electric potential are set out in chapter 4.2.1.
- to evaluate the ecological and landscape value are set out in chapter 4.2.2.




Figure 6: Classification scheme regarding the potential appropriateness of a river stretch as location for small hydropower plants from a regional, strategic perspective.

FAVOURABLE	LESS-FAVOURABLE	NON-FAVOURABLE	EXCLUSION
for hydro-electrical exploitation	for hydro-electrical exploitation	for hydro-electrical exploitation. Strong interest for conservation	hydro-electrical exploitation forbidden by law
complying with the legal environmental (and other) standards, construction of SHPs in general possible	additional aspects and in- depth assessment weighing all relevant criteria indispensable Next to complying with legal environmental standards, possibly further or stricter requirements may be necessary	SHPs possible only in exceptional cases (e.g. auto-supply)	No hydro-electrical exploitation possible since protected areas where any interventions are forbidden by law

Figure 6 illustrates the classification scheme defining the potential appropriateness resulting from the comparison of the two considered aspects.

²⁹ Important refurbishments or upgrading of existing operating plants, requiring a new concession can lead to further environmental deterioration; therefore such cases should be evaluated with the same procedure applied on new installations

This first level provides a coarse assessment from a regional and strategic point of view that needs to be considered at the local level, where the actual authorisation decision with a more in-depth assessment takes place. For the evaluation of the individual application all sustainability aspects have to be considered and all relevant criteria of the project have to be weighted³⁰.

The aspects considered at regional level have therefore to be complemented at the local level with installation- and detailed site-specific criteria (see chapter 4.3.1) and further socio-economic criteria (see chapter 4.3.2)

The following subchapters provide a non-exhaustive list of suggestions for common criteria and for possible additional criteria. Whereas a selection of a set of Alpine-wide common criteria is desirable, the final selection and weighting³⁰ of the criteria - being intrinsically a political decision - as well as the determination of classification boundaries should be chosen individually by the competent authority at regional level (province, canton or other competent authorities) or national level in order to give proper attention to the specific situation and national and regional factors³⁰.

Some of the suggested criteria are quantitative, some of qualitative nature, some need expert judgment.

4.2 The regional strategy: classification of river stretches with respect to potential appropriateness for SHPs

4.2.1 Criteria for the evaluation of the theoretical hydroelectric potential

The theoretical hydroelectric potential of the individual river stretches within a region can be estimated and evaluated by way of the following criteria:

CRITERIA	UNIT	DESCRIPTION
Specific potential energy production or	kWh/m	Potential energy production divided by the length of the river stretch (Subdivision of the river system can be done e.g. from junction to junction or for a fixed length of river (e.g. 1 km))
Specific potential power output or	kW/m	Potential power output divided by the length of the river stretch (see above).
Necessary length of water diversion for producing a certain power output	m/kW	Inverse of the specific potential power output (e.g. calculated for a fixed power output of 500 kW or 1MW)
Specific head	m/m	Head divided by the length of the river stretch. Can be designated for the length of river stretches, for river stretches from junction to junction or for a forgone length of river (e.g. 1 km).

The necessary input variables for calculating the above criteria for the hydroelectric potential are runoff, head and length of the river stretch that can be established on the basis of spatial data by application of geographic information systems. With respect to runoff, uncertainties and temporal variability have to be taken into account.

The final evaluation classifies the theoretical hydroelectric potential of the river stretches into categories ranking from „high“ which means particularly apt for hydropower use from a hydroelectric potential point of view, to „little“ meaning not apt for hydropower user from a hydroelectric potential point of view³¹.

³⁰ Indications of classification boundaries and examples of how to aggregate and weight different criteria can be found in the annex's good practice examples, e.g. in the strategy "water-use" of the Canton of Berne (Switzerland): www.bve.be.ch or in the list of criteria of the Province of Tyrol (Austria): www.tirol.gv.at/fileadmin/www.tirol.gv.at/regierung/downloads/kriterienkatalog.pdf

³¹ In the strategy „water use“ of the Canton of Berne (Switzerland), e.g. the following categories of theoretical hydroelectric potential, defined by the specific power output, are used: 3 – 300 kW/m – high hydroelectric potential; 0.3 – 3 kW/m – medium potential; 0.1 – 0.3 kW/m – small potential; < 0.1 kW/m – very small potential (not represented)

4.2.2 Criteria assessing the ecological and landscape value

The ecological and landscape value of the individual river stretches within a region can be evaluated by way of the following criteria:

CRITERIA	DESCRIPTION
Classification of the ecological status	<i>Classification of river stretches according to WFD or Swiss Modular Stepwise Procedure ³²</i>
Hydrologic regime	Minimal flow, flow fluctuation, impounded length...
Morphology	Natural structure and barrier free flow path, longitudinal connectivity
Biology (qualitative and quantitative)	Fish, macrozoobenthos, diatomea...
Possible additional criteria: Chemical water quality Thermal regime Bedload	
Type of water body	
Rarity of the water body type	
Sensibility of the water body type	
Rarity of the high status class within the water body type	
Importance as habitat	
Rare / protected habitats	Importance; fish spawning area, etc.
Importance for protected species	Fauna and flora
Rich species spectrum / diversity	Fauna and flora
Possible additional criteria: longitudinal connectivity transversal connectivity Fish waters	Waters suitable to sustain natural fish populations
Landscape value	
Protected areas	Depending on the protection level and the interaction with the water body
Recreation value	
Beauty	Scenic attraction, symbolic value, local identity
Importance for the whole river system	Considering the specific function for the other stretches in the river or (sub)basin

³² www.modul-stufen-konzept.ch

Sites / zones that can justify the classification “non-favourable for hydropower use”

Even if no limitation for hydropower is set by law, sites with high ecological and landscape value should get special protection and therefore be considered as “non-favourable for hydropower use”³³. Such sites are listed below:

Sites located in one of the following zones:

National parks

Water related Nature2000 sites

Water related landscapes or natural monuments of national / regional importance

River stretches and biotopes of national / regional importance e.g. according to the rarity of type or naturalness or specific function for the river system

Revitalised or river stretches foreseen to be revitalised

Sites with one of the following characteristics:

Floodplains (wetlands, marshlands, riparian zones, dynamic and braided river stretches ...)

Important spawning areas

Residual flow stretches³⁴

River stretches with fish and crayfish populations of national importance

Interference with the protection of water resources for drinking water supply (drinking water protection zones)

Exclusion areas

Based on the applicable legislation, there may be sites where, due to their unique ecological and landscape value or to local spatial planning, any further use for hydropower generation is forbidden by law. These cases represent “Exclusion areas” and depend on the locally valid legislation, thus they are not explicitly listed as criteria.

4.3 The local assessment for new installations: Evaluating the site- and project-specific pros and cons

Whereas at the regional level the evaluation of the appropriateness is carried out irrespective of concrete applications, the local assessment is necessary only in response to an application for authorisation.

At the regional level neither socio-economic nor installation specific criteria have been considered. In order to base the authorisation decision on all sustainability dimensions, the following list of criteria for the local assessment complements the ones of the regional level with installation-specific and further socio-economic aspects including impacts on other sectors. For some criteria, uncertainties and temporal variability of the underlying data have to be appropriately taken into account.

Considering that the final decision about authorisation can only be taken according to the existing national / regional instruments and legal framework (e.g. environmental impact assessment,...), this non exhaustive list of evaluation criteria should be adjusted in accordance with the aspects considered by existing instruments.

³³ E.g. in the Austrian National River Basin Management Plan (March 2010) the Austrian Federal States (Bundesländer) are supposed to proceed with a regional planning which may lead to an assignment of water bodies where the river stretches having been classified in a very good status (class 1 – high status) will be protected in any case for the future.

³⁴ River stretches are considered as residual flow stretches as long as they are significantly affected by the withdrawal.

4.3.1 Installation- and site-specific criteria

CRITERIA	UNIT	DESCRIPTION
Energy balance or "energy payback ratio"		Energy input for the construction of the installation and operation compared to the energy production (e.g. expressed as number of years until energy output > energy input);
Specific investments	€/kWh	Euros (or Swiss Francs) per expected annual production of the installation
Use of hydroelectric potential	%	Extent of use of available potential including consideration of residual flow requirements and qualitative description of the reasons if the available potential is only partly used.
Minimisation of impacts		Measures going beyond minimum legal requirements (e.g. with respect to ecological flow, fish pass, bed load, aesthetics, natural scenery, etc.)
Synergies with existing infrastructures		Infrastructure plants or existence of a deactivated plant
Sewage dilution coefficient on the residual flow stretch		
Ecological impacts downstream and upstream		
Integration in the landscape		
Grid relevancy		e.g. Importance for the grid stability
Possible additional criteria for the comparison of applications competing on the same river stretch:		
Specific power output	kW/m	Power output related to the length of the residual flow stretch and impounded river length.

4.3.2 Further socio-economic criteria

CRITERIA	DESCRIPTION
Conflicts with other water users	Locally, downstream and upstream
Conformity with local spatial planning	
Necessity of further infrastructure for construction and operation	Access, power-lines, etc.
Effect on tourism	Potential positive and negative effects on tourism
Regional economic effects	Taxes, income for the public; investments in local economy, induced employment
Self supply necessity	If distance to the public grid too long and no better environmental option is given.
Relevant certifications ³⁵	e.g. green energy labels; ISO 14000 ; ...
Other socio-political considerations	

³⁵ Good Practice Example "CH2OICE" provided in Annex 1, illustrates this criteria

www.alpconv.org

**Permanent Secretariat
of the Alpine Convention**

Herzog-Friedrich-Straße 15
A-6020 Innsbruck
Tel.: + 43.512.588.589 - 0
Fax: + 43.512.588.589 - 20
Email: info@alpconv.org

Branch office

Viale Druso - Drususallee 1
I-39100 Bolzano - Bozen
Tel.: +39 0471 055 352
Fax: +39 0471 055 359

